CE15 Contactor Specifications

| | 45 mm Cutler-Hammer CE | 15 Co | ontactor | Specific | ations | | | |
|-------------------------------|---|-------|---|----------|---------------|-------------|--------|--------|
| Contactor Model | | | CE15AN | CE15BN | CE15CN | CE15DN | CE15EN | CE15FN |
| Insulation Voltage | AC | (V) | 690 Volts AC | | | | | |
| Ammore Doting | Max. UL Current (AC3) ¹ | (A) | 7 | 10 | 12 | 18 | 25 | 32 |
| Ampere Rating | AC1 Thermal Current (600V) ² | (A) | 20 | 20 | 20 | 32 | 32 | 32 |
| | 200V | | 1.5 | 2 | 3 | 5 | 5 | 7.5 |
| Maximum Power (hp) of | 230/240V | (hp) | 1.5 | 2 | 3 | 5 | 7.5 | 10 |
| Three-Phase Motors | 460/480V | | 3 | 5 | 7.5 | 10 | 15 | 20 |
| | 575V | (hp) | 5 | 7.5 | 10 | 15 | 20 | 25 |
| Maximum Power (hp) of | 115V | (hp) | 0.25 | 0.5 | 0.5 | 1 | 2 | 2 |
| Single-Phase Motors | 230/240V | (hp) | 0.5 | 1 | 2 | 3 | 3 | 5 |
| | 230/240V | (kW) | 1.1 | 1.5 | 2.2 | 4 | 5.5 | 7.5 |
| Maximum Power (kw) of | 415/440V | (kW) | 2.2 | 4 | 5.5 | 7.5 | 11 | 15 |
| Three-Phase Motors AC3 | 500/550V | (kW) | 2.2 | 4 | 5.5 | 7.5 | 11 | 15 |
| Category ¹ | 500V | (kW) | 4 | 5.5 | 7.5 | 11 | 15 | 18.5 |
| | 600V | (kW) | 1.5 | 2.2 | 4 | 5.5 | 7.5 | 10 |
| Auxiliary Contacts Electrica | al Capacity | | A600 ⁴ | | | | | |
| SCCR | | | 5kA | | | | | |
| Coil Voltage Operating Lim | its | | A.C.Pick-Up 85-110% Rated Control Voltage / A.C. Drop-Out 20-75% Rated Control Voltage | | | | | |
| Average Coil Power Requir | ements / Coil current (A) = VA/Coil Voltage | | A.C. Pick-Up (VA) 80-100 / A.C. Sealed (VA) 9-12 | | | | | |
| Power Factor | | | Pick-Up .65 / Sealed .35 | | | | | |
| Coil Operating Time at Rate | d Coil Voltage | | Pick-Up (ms) 10-25 / Drop-Out (ms) 6-18 | | | | | |
| Maximum Operating Freque | ency (No-Load Operation) | | 3000 Operations / Hour | | | | | |
| Mechanical Durability | | | 10,000,000 Operations | | | | | |
| Electrical Durability | 1,000,000 Operations | | | | | | | |
| Operating Ambient Temperature | | | -25° to +55°C | | | | | |
| Electrical Protection Degree | | | IP20 (IP10 for GH15ET and GH15FT) | | | | | |
| Mounting | | | Screw or 35mm DIN Rail | | | | | |
| Wire Sizes | Line / Load | | #10 - #14 AWG stranded recommended #14 - #8 stranded recommended | | | | | |
| WIIE SIZES | Control & Auxiliary Contacts | | | #12 - ; | #14 AWG (stra | nded recomm | ended) | |
| Line/Load Tighting Torque | N•m (lb•in) | | 7 | 7 | 7 | 15 | 15 | 15 |

1. AC3 type loads consist of squirrel cage three phase motors.

2. AC1 non-inductive or slightly inductive loads. Typically resistive loads (i.e. furnaces, ovens, etc.)

3. Type 2 coordination is a protection category for IEC 60947-4-1. Section 8.2.5.1 specifies that Type 2 coordination requires that, under short circuit conditions, the contactor or starter shall cause no danger to persons or installations and shall be suitable for further use. The risk of minor contact welding is possible.

4. NEMA ICS 5-2000. For more information, refer to Control Circuit Contact Electrical Ratings, page MRC-tMRC-111.


| | Cutler-Hammer CE15 Series Contactor Part Numbers | | | | | | | | | | |
|-------------------|--|-------------|-------|--------------------|-----|------------------|----------------------------|--|--------------------|------------------------------|--|
| | Cutler- | | | Number of Contacts | | | | Additiona | l Contacts | | |
| IEC FRAME SIZE | Hammer Contactor | Part Number | Price | Main | | Contacts uded | Coil Voltage and Frequency | Maximum Contact | Type of Additional | | |
| | Model | | | | N.0 | N.C. | | Block Arrangement | Contact Block | | |
| | CE15AN | CE15AN4AB | | 4 | | | 110-120VAC 50-60Hz | | | | |
| | GEIJAN | CE15AN4BB | | 4 | | | 220-240VAC 50-60Hz | | | | |
| | CE15BN | CE15BN4AB | | 4 | | | 110-120VAC 50-60Hz | | | | |
| | CEIDBIN | CE15BN4BB | | 4 | | | 220-240VAC 50-60Hz | | | | |
| | CE15CN | CE15CN4AB | | 4 | | | 110-120VAC 50-60Hz | Up to two auxiliary contact blocks may | Side mount | | |
| 45 mm | CEISCN | CE15CN4BB | | 4 | | | 220-240VAC 50-60Hz | | | C320KGS3: 1 N.O. / 1 N.C. | |
| 45 ////// | CE15DN | CE15DNS3AB | | 3 | 1 | | 110-120VAC 50-60Hz | be added to CE15 contactors | C320KGS1: 1 N.O. / | | |
| | CEIDDN | CE15DNS3BB | | 3 | 1 | | 220-240VAC 50-60Hz | (one per side). | 1 N.C. | | |
| | | CE15ENS3AB | | 3 | 1 | | 110-120VAC 50-60Hz | | | | |
| | CE15EN | CE15ENS3BB | | 3 | 1 | | 220-240VAC 50-60Hz | | | | |
| | CE15FN | CE15FNS3AB | | 3 | 1 | | 110-120VAC 50-60Hz | | | | |
| | GEIDEN | CE15FNS3BB | | 3 | 1 | | 220-240VAC 50-60Hz | | | | |

Note: Holding circuit contact(s) supplied standard: a N.O. auxiliary contact block is mounted on the right-hand side. (On Sizes A-C, contact occupies fourth power pole position - no increase in width.)
Motor Controls
tMRC-108


FAT-N Motor Control Dimensions

| | Size and Dimensions (Inches) | | | | | | | | | | |
|-----------------|------------------------------|------|------|------|------|------|----------|-----------------------|----|-----------------------|--|
| | Contactor Type | | | | | | | | | | |
| Product | IEC Size | Wide | High | Deep | | | Mounting | Ohia Waiaht in Dawada | | | |
| | | A | В | С | D | Ε | E1 | F | G | Ship Weight in Pounds | |
| Starters | A-F | 1.80 | 5.86 | 3.28 | 1.36 | 5.19 | 5.39 | - | 54 | 1.75 | |
| Contactors | A-C | 1.80 | 2.96 | 3.26 | 1.36 | 1.96 | - | - | 54 | 1.3 | |
| Contactors | D-F | 1.80 | 2.96 | 3.26 | 1.36 | 1.96 | - | - | 54 | 1.4 | |
| Overload Relays | 32 Amp | 1.77 | 4.13 | 3.69 | 1.36 | 3.74 | - | - | - | 0.8 | |

IEC contactor sizes A-F, CE15



IEC starter sizes A-F, AE16



Electrical Ratings Charts

Motor Current Ratings

| | 115 | VAC | 200 | VAC | 230 | 460 VAC | | |
|----------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|--|
| Motor HP | 1-Phase (A) | 3-Phase (A) | 1-Phase (A) | 3-Phase (A) | 1-Phase (A) | 3-Phase (A) | 3-Phase (A) | |
| 1/10 | 3.0 | | | | 1.5 | | | |
| 1/8 | 3.8 | | | | 1.9 | | | |
| 1/6 | 4.4 | | 2.5 | | 2.2 | | | |
| 1/4 | 5.8 | | 3.3 | | 2.9 | | | |
| 1/3 | 7.2 | | 4.1 | | 3.6 | | | |
| 1/2 | 9.8 | 4.4 | 5.6 | 2.5 | 4.9 | 2.2 | 1.1 | |
| 3/4 | 13.8 | 6.4 | 7.9 | 3.7 | 6.9 | 3.2 | 1.6 | |
| 1 | 16.0 | 8.4 | 9.2 | 4.8 | 8.0 | 4.2 | 2.1 | |
| 1 1/2 | 20.0 | 12.0 | 11.5 | 6.9 | 10 | 6.0 | 3.0 | |
| 2 | 24.0 | 13.6 | 13.8 | 7.8 | 12 | 6.8 | 3.4 | |
| 3 | 34.0 | 19.2 | 19.6 | 11.0 | 17 | 9.6 | 4.8 | |
| 5 | 56.0 | 30.4 | 32.2 | 17.5 | 28 | 15.2 | 7.6 | |
| 7 1/2 | 80.0 | 44.0 | 46.0 | 25.3 | 40 | 22 | 11 | |
| 10 | 100.0 | 56.0 | 57.5 | 32.2 | 50 | 28 | 14 | |
| 15 | | 84.0 | | 48.3 | | 42 | 21 | |
| 20 | | 108.0 | | 62.1 | | 54 | 27 | |
| 25 | | 136.0 | | 78.2 | | 68 | 34 | |
| 30 | | 160.0 | | 92 | | 80 | 40 | |
| 40 | | 208.0 | | 120 | | 104 | 52 | |
| 50 | | 260.0 | | 150 | | 130 | 65 | |
| 60 | | | | 177 | | 154 | 77 | |
| 75 | | | | 221 | | 192 | 96 | |
| 100 | | | | 285 | | 248 | 124 | |

The motor currents are approximate and not guaranteed to be accurate. This chart is provided as a guideline only. Values were extrapolated from NEC Tables 430-148 and 430-150. Motor currents should be taken from the motor's nameplate. It is the user's responsibility to properly size their motor control devices.

Control Circuit Contact Electrical Ratings

NEMA Mechanical Switching Ratings and Test Values for DC Control Circuit Contacts

| | Thermal | Maximum | Make or Brea | | | | | | | |
|-------------------------------|-----------------------------------|--------------------------|--------------|------------------|-------------|--|--|--|--|--|
| Contact Rating Designation | Continuous Test Current (A) | est Current 125 Volts 25 | | 301 to 600 Volts | Voltamperes | | | | | |
| P300 | 5.0 | 1.1 | 0.55 | | 138 | | | | | |
| P600 | 5.0 | 1.1 | 0.55 | 0.20 | 138 | | | | | |
| Q300 | 2.5 | 0.55 | 0.27 | | 69 | | | | | |
| Q600 | 2.5 | 0.55 | 0.27 | 0.10 | 69 | | | | | |
| R300 | 1.0 | 0.22 | 0.11 | | 28 | | | | | |

This chart is provided as a guideline only, and the ratings and values are not guaranteed to be accurate. It is the users' responsibility to properly size their control circuit devices.

The chart values are from NEMA Standard ICS 5-2000, Table 1-4-2.

| NEN | NEMA Mechanical Switching Ratings and Test Values for AC Control Circuit Contacts | | | | | | | | | | |
|-------------------------------|---|------|---------------------|------|-------|------|-----------------|------|-------|-------|-------|
| | Thermal | | Voltamperes | | | | | | | | |
| Contact Rating Designation | Continuous Test Current | 120 | 120 Volts 240 Volts | | | | 480 Volts 600 V | | | Volts | |
| Designation | (A) | Make | Break | Make | Break | Make | Break | Make | Break | Make | Break |
| A300 | 10 | 60 | 6.00 | 30 | 3.00 | | | | | 7200 | 720 |
| A600 | 10 | 60 | 6.00 | 30 | 3.00 | 15 | 1.50 | 12 | 1.20 | 7200 | 720 |
| B300 | 5 | 30 | 3.00 | 15 | 1.50 | | | | | 3600 | 360 |
| B600 | 5 | 30 | 3.00 | 15 | 1.50 | 7.5 | 0.75 | 6 | 0.60 | 3600 | 360 |
| C600 | 2.5 | 15 | 1.5 | 7.5 | 0.75 | 3.75 | 0.375 | 3.00 | 0.30 | 1800 | 180 |

This chart is provided as a guideline only, and the ratings and values are not guaranteed to be accurate. It is the users' responsibility to properly size their control circuit devices. The chart values are from NEMA Standard ICS 5-2000, Table 1-4-1.

IEC Utilization Categories

| Current | Category | Typical Applications | Relevant IEC Product Standard ³ | | | |
|-----------|----------|--|--|--|--|--|
| | AC-1 | Non inductive or slightly inductive loads, resistance furnaces, heaters | | | | |
| | AC-2 | Slip-ring motors: switching off | | | | |
| | AC-3 | Squirrel-cage motors: starting,switching off motors during running most typical industrial application | | | | |
| | AC-4 | Squirrel-cage motors: starting, plugging ¹ , inching ² | | | | |
| | AC-5a | Switching of electric discharge lamps | | | | |
| | AC-5b | Switching of incandescent lamps | c00.17.4 | | | |
| | AC-6a | Switching of transformers | 60947-4 | | | |
| | AC-6b | Switching of capacitor banks | | | | |
| | AC-7a | Slightly inductive load in household appliances: mixers, blenders | | | | |
| 40 | AC-7b | Motor-loads for household applications: fans, central vacuum | | | | |
| AC | AC-8a | Hermetic refrigerant compressor motor control with manual resetting overloads | | | | |
| | AC-8b | Hermetic refrigerant compressor motor control with automatic resetting overloads | | | | |
| | AC-12 | Control of resistive loads and solid state loads with opto-coupler isolation | | | | |
| | AC-13 | Control of solid state loads with transformer isolation | 60947-5 | | | |
| | AC-14 | Control of small electromagnetic loads | | | | |
| | AC-15 | Control of AC electromagnetic loads | | | | |
| | AC-20 | Connecting and disconnecting under no-load conditions | | | | |
| | AC-21 | Switching of resistive loads, including moderate loads | 60947-3 | | | |
| | AC-22 | Switching of mixed resistive and inductive loads, including moderate overloads | - | | | |
| | AC-23 | Switching of motor loads or other highly inductive loads | | | | |
| | A | Protection of circuits, with no rated short-time withstand current | C0047.0 | | | |
| AC and DC | В | Protection of circuits, with a rated short-time withstand current | 60947-2 | | | |
| | DC-1 | Non-Inductive or slightly inductive loads, resistance furnaces, heaters | | | | |
| | DC-3 | Shunt-motors, starting, plugging ¹ , inching ² , dynamic breaking of motors | | | | |
| | DC-5 | Series-motors, starting, plugging ¹ , inching ² , dynamic breaking of motors | 60947-4 | | | |
| | DC-6 | Switching of incandescent lamps | | | | |
| | DC-12 | Control of resistive loads and solid state loads with opto-coupler isolation | | | | |
| 00 | DC-13 | Control of DC electromagnetics | | | | |
| | DC-14 | Control of D.C. electromagnetic loads having economy resistors in the circuit | 60947-5 | | | |
| | DC-20 | Connecting and disconnecting under no-load conditions | | | | |
| | DC-21 | Switching of resistive loads, including moderate overloads | | | | |
| | DC-22 | Switching of mixed resistive and inductive loads, including moderate overloads (i.e. shunt motors) | 60947-3 | | | |
| | DC-23 | Switching of highly inductive loads (i.e. series motors) | | | | |

¹Plugging - Stopping a motor rapidly by reversing the primary power connections.
 ²Inching - Energizing a motor repeatedly for short periods to obtain small incremental movements.
 ³IEC Standards must be purchased from the International Electrotechnical Commission